

Requirements of the venue “Das Wormser”

Dogs are not permitted in the venue!

Smoking is generally prohibited in the venue

Escape routes must be kept clear at all times. It must be possible to easily open the full width of doors along escape routes from the inside. Escape routes, exit doors, emergency exits and their markings must not be blocked, covered or otherwise made unrecognizable. Corridors and aisles must not be obstructed at any time during the event by objects placed in them or protruding into them. Corridors and aisles serve as escape routes in the event of danger. Fire and smoke protection doors must not be held open by wedges or other objects.

Fire alarms, hydrants, fire extinguishers and fire pipes, smoke dampers, trigger points for smoke extraction systems, smoke detectors, telephones and air inlets and outlets for heating and ventilation systems, smoke extraction systems, their signs and the green emergency exit signs must be accessible and visible at all times; they must not be blocked, covered or otherwise obscured.

All electrical devices used must have a DGUV-V test. Explicit attention will be paid to this during booth approval; if the equipment has not been tested, the fire safety officer reserves the right not to approve the equipment. Electrical (switching) systems must not be accessible to visitors and must be adequately secured. In the event of non-compliance, the fire safety officer may demand that the equipment be dismantled.

The insertion of bolts and anchors, the hammering in of nails and the drilling of holes is prohibited.

Any waste produced must be disposed of by the exhibitors themselves after the event. The sites must be left clean.